



XP95 Isolator

Addressable – Devices

Part No. 55000-720APO

www.illuminoignis.co.uk

Product Details

The Isolator is placed at intervals on the loop and ensures that, in the case of a short circuit, only the section between the isolators will be affected. When the short circuit is removed, the isolators automatically restore power and data to the isolated section. The Isolator can only be used with an Isolator base and will not fit a standard addressable base

Key Features

- Detects wiring short-circuits using patented technology
- Minimizes disruption from short circuits
- Automatic de-isolation on short-circuit removal
- Up to 20 detectors (or equivalent) may be installed between isolators

Technical Specifications

All data is supplied subject to change without notice. Specifications are typical at 24 V, 25°C and 50% RH unless otherwise stated.

Operating voltage	17 V – 28 V dc (max dc voltage range)
Digital communication	XP95, Discovery and CoreProtocol compatible
Modulation voltage	5 – 9 V peak to peak
Quiescent current	35 µA
Surge current	0 mA
Maximum current drawn	8.5 mA
Maximum line impedance	50 Ω
Operating temperature	- 30 °C to +80 °C
Standards and approvals	CPR, LPCB, VdS
Dimensions	100 mm diameter x 3.5 cm height
Materials	White flame-retardant polycarbonate

Note:

For further details on Short-circuit isolation, please refer to PP2090 – Short-circuit isolation – available from www.apollo-fire.co.uk

Isolator Base

The Isolator Base is only suitable for use with the Isolator.



EMC Directive 2014/30/EU

The Isolator and Isolator Base comply with the essential requirements of the EMC Directive 2014/30/EU, provided that they are used as described in this datasheet.

A copy of the Declaration of Conformity is available from the Apollo website: www.apollo-fire.co.uk

Conformity of the Isolator and the Isolator Base with the EMC Directive, does not confer compliance with the directive on any apparatus or systems connected to them.

Construction Products Regulation 305/2011/EU

The Isolator complies with the essential requirements of the Construction Products Regulation 305/2011/EU.

A copy of the Declaration of Performance is available from the Apollo website: www.apollo-fire.co.uk